SUSPENDED ACCESS SYSTEMS LTD

Cradle Engineering and Fall Protection Specialist

REPORT OF INSPECTION OF PERSONAL FALL PROTECTION SYSTEMS
(10.43 Issue 1)

We hereby certify that the following equipment has been inspected in accordance with BS7883:2019 Section 4, and where applicable the Lifting Operations and Lifting Equipment Regulations 1998 (LOLER) and BS7985:2013.

This inspection report remains valid until 08.07.2023 subject to no repairs, modifications or exceptional circumstances occurring to the personal fall protection systems.

Report Nº: FPS/ 863 Inspection date: 09.01.2023 Engineer: M Parfett

Name and address of the duty holder for whom the inspection was made: Rubynest Limited PO Box 332 Tadworth Surrey KT20 9BW
The address at which the inspection was made: Storage area White Collar Factory 210 Old Street London EC1V 9BR

Description of lifting equipment or accessory	Serial Nº	Status P -Pass CP – Conditional pass F - Fail	Test load applied (If none, state NONE)	Working load limit in kg	Safe to use?	Defects noted, or repairs required (if none, state NONE), and date by which it should be repaired or re-inspected
Rigs – DW200 Abseil portable rigs	AF000203	CP	35nM	250kg	Yes	NONE

Signed: **for and on behalf of Suspended Access Systems Limited**

NEXT EXAMINATION DUE: 09.07.2023

Notes:

1. Is this the inspection prior to first use? **Yes** ☐ **No** ☒
2. Is this inspection carried out after the occurrence of an exception event? **Yes** ☐ **No** ☒
   If yes provide details of the reason why an interim inspection has been carried out.
3. Is this a supplementary inspection? **Yes** ☐ **No** ☒
   If yes provide details of the reason why an interim inspection has been carried out.